Carnhope Irrigation District #7 Annual Drinking Water Quality Report

Mandatory Health-Related Standards Are Established by the Washington State Department of Health

Highest Detected Level					
Parameter	Unit of	MCL	MCLG	Source	Likely Source of Contamination
	Measure			4	
Microbiology					
26 Tests were taken during this reporting period					
Total Coliform Bactria				No Detections	Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be
Fecal Coliform and E. Coli Inorganic Chemicals				No Detections	present. Coliforms were found in more samples than allowed and this is a warning of potential problems.
Nitrate	mg/l	10	10	1.	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
				Samples Taken 11/30/	18
PFAS					Per- and polyfluoroalkyl substances (PFAS) are a family of chemicals used since the 1950s.
Perflourobutanesulfonic	PFBS/ug/l			No Detection	to manufacture stain-resistant, water-resistant, and non-stick products.
Perfluoroheptanoic acid	PFHpa/ug/l			No Detection	PFAS are widely used in common consumer products as coatings, on food packaging,
Perfluorexanesulfonic Acid	PFHxS/ug/l			No Detection	outdoor clothing, carpets, leather goods, ski and snowboard waxes, and
Perfluorononanoic aid	PFNA/ug/l			No Detection	Certain types of firefighting foam—historically used by the U.S. military, local fire departments and airports—may contain PFAS.
Perfluorooctanesulfonic acid	PFOS/ug/l			No Detections	
Perfluorooctanoic acid	PFOA/ug/l			No Detections	
	Lead	0.015			No Detections above MCL
	Copper	1.3			No Detections above MCL

As you can see by the table, our system had no violations above the allowed Maximum Contaminant Levels. We're proud that your drinking water meets or exceeds all Federal and State requirements.

CHECK OUT ALERT SPOKANE
AT WWW.ALERTSPOKANE.COM
TO RECIEVE EMERGENCY
INFORMATION OVER THE
TELEPHONE!

Abbreviations Notes

mg/L= milligrams per liter

ND= Not Detected

ppm = parts per million

ppb = parts per billion

pCi/L = picocuries per liter (a measure of radioactivity)

AL = Action Level
concentrations of a constituent

which, if exceeded, triggers

treatment or other

Maximum Contaminant Level or

MCL: The highest level of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in

MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Federal Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. Drinking water, including bottles water, may reasonably be expected to contain small amounts of some contaminants. The presence of contaminants does not indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline(800-426-4791)

Some People may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemo-therapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen risk of infection to *Cryptosporidiam* and other microbial contaminatns are available from the Safe Drinking Water Hotline (800-426-4791)

From Your Water Utility

Carnhope Irrigation District #7 4613 E. Third Ave. Spokane, WA 99212 Phone 509-536-9180

E-mail: carnhope7@comcast.net
Contact Person: Terry Squibb
Superintendent
Regular Scheduled Board Meetings are held
the first Monday of every month at 7:00 P.M.