

**Carnhope Irrigation District #7
2021 Annual Drinking Water Quality Report
Mandatory Health-Related Standards Are Established by the Washington State Department of Health**

Parameter	Unit of Measure	MCL	MCLG	Highest Detected Level				Likely Source of Contamination
				Source				
				4				
Microbiology								
24 Tests were taken during this reporting period								
Total Coliform Bactria				No Detections				Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present.
Fecal Coliform and E. Coli				No Detections				
Inorganic Chemicals								
Nitrate	mg/l	10	10				1.26	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
				Samples Taken 8/18/21				
PFAS								
Perflourobutanesulfonic	PFBS/ug/l						No Detection	Per- and polyfluoroalkyl substances (PFAS) are a family of chemicals used since the 1950s . to manufacture stain-resistant, water-resistant, and non-stick products.
Perfluoroheptanoic acid	PFHpA/ug/l						No Detection	
Perfluorexanesulfonic Acid	PFHxS/ug/l						No Detection	PFAS are widely used in common consumer products as coatings, on food packaging, outdoor clothing, carpets, leather goods, ski and snowboard waxes, and
Perfluorononanoic acid	PFNA/ug/l			No Detection				Certain types of firefighting foam—historically used by the U.S. military, local fire departments, and airports—may contain PFAS.
Perfluorooctanesulfonic acid	PFOS/ug/l						No Detections	
Perfluorooctanoic acid	PFOA/ug/l						No Detections	Samples taken 9/13/18
Lead		0.015		No Detections above MCL				10 samples taken 9/24/20
Copper		1.3		No Detections above MCL				10 samples taken 9/24/20

Abbreviations
 ND= Not Detected
 ppm = parts per million
 ppb = parts per billion
 pCi/L = picocuries per liter (a measure of radioactivity)

 AL = Action Level - concentrations of a constituent which, if exceeded, triggers treatment or other requirements
 mg/L= milligrams per liter

Notes

Maximum Contaminant Level or MCL:The highest level of a contaminant that is allowed in drinking water.
Maximum Contaminant Level Goal or MCLG:The level of a contaminant in drinking water below which there is no known or expected risk to health.
Treatment Technique or TT: A required process intended to reduce the level of a
Federal Action Level:The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a

Drinking water, including bottled water, may reasonably be expected to contain small amounts of some contaminants. The presence of contaminants does not indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline(800-426-4791)

Some People may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemo-therapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to

As you can see by the table, our system had no violations above the allowed Maximum Contaminant Levels. We're proud that your drinking water meets or exceeds all

LIMIT WATER USE TO 45 MINUTES OR LESS PER STATION. WATER IN THE EARLY MORNING OR THE EVENING. THIS WILL CONSERVE WATER AND PREVENTS WASTE!!!

From Your Water Utility
 Carnhope Irrigation District #7
 4613 E. Third Ave.
 Spokane, WA 99212
 Phone 509-536-9180

E-mail: carnhope7@comcast.net
 Contact Person: Terry Squibb
 Superintendent

Regular Scheduled Board Meetings are held the first Monday of every month at 7:00 P.M.