

**Hutchinson Irrigation District #16
Annual Drinking Water Quality Report**
Mandatory Health-Related Standards Are Established by the Washington State Department of Health

Parameter	Unit of Measure	MCL	MCLG	Highest Detected Level		Likely Source of Contamination
				Source	5	
Microbiology						
24 Tests were taken during this reporting period						
Total Coliform Bacteria				No Detections		Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this is a warning of potential problems.
Fecal Coliform and E. Coli				No Detections		
Inorganic Chemicals						
Nitrate	mg/l	10	10	0.796	12/12/12	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Lead and Copper at the Customers Tap						
Lead		AL=0.015 mg/l		Sample taken 12/17/12		No detection above action level
Copper		AL=0.2 mg/l		Sample taken 12/17/12		No detection above action level

As you can see by the table, our system had no violations above the allowed Maximum Contaminant Levels. We're proud that your drinking water meets or exceeds all Federal and State requirements.

WATER CONSERVATION IS
IMPORTANT.

DON'T WATER YOUR LAWN WHEN IT'S
RAINING
IT WASTES WATER AND CAN COST
YOU MONEY!

Abbreviations

ND= Not Detected
ppm = parts per million
ppb = parts per billion
pCi/L = picocuries per liter (a measure of radioactivity)
AL = Action Level - concentrations of a constituent which, if exceeded, triggers treatment or other requirements
mg/L= milligrams per liter
SRL=State reporting level

Notes

Maximum Contaminant Level or MCL:The highest level of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal or MCLG:The level of a contaminant in drinking water below which there is no known or expected risk to health.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Federal Action Level:The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Drinking water, including bottled water, may reasonably be expected to contain small amounts of some contaminants. The presence of contaminants does not indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791)

Some People may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemo-therapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen risk of infection to *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

From Your Water Utility

Hutchinson Irrigation District #16
618 N Sargent Rd
Spokane, WA 99212
ph: 509-926-4634

Contact Person: Terry Squibb
Superintendent

Regular Scheduled Board Meetings are held every second Monday of the month at 7:30. p.m.