

Trentwood Irrigation District No. 3
2025 Annual Drinking Water Quality Report

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels. Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, person who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

Mandatory Health-Related Standards Are Established by the Washington State Department of Health

			Highest level recorded				
Parameter	Units	MCL	Well #3	Well#4	Well #5	Well #6	Comments
<u>Microbiology</u> Total Coliform	Present/ Not-Present	Presence in 5% of monthly sample or in one routine and one follow up and one is fecal or E. Coli	65 representative samples taken this year 1 present for Total Coliform 0 present for E. Coli				Repeat samples were absent for Total Coliform
Nitrate	mg/L	10	2.61	1.94	1.92	2.18/2.13/1.96	
Iron	mg/L	0.3				0.198	
Arsenic	mg/L	0.01	.00351				
PFAS							
PFAS	Units	MCL	Well #3	Well#4	Well #5	Well#6	Comments
PFOA Perfluorooctanoic acid	ng/L	N/A	ND		ND	ND	
PFOS Perfluorooctanesulfonic acid	ng/L	N/A	ND		ND	ND	
PFHxS Perfluorohexanesulfonic acid	ng/L	N/A	ND		ND	ND	
PFNA Perfluorononanoic acid	ng/L	N/A	ND		ND	ND	
PFBS Perfluorobutanesulfonic acid	ng/L	N/A	ND		ND	ND	
PFHpA Perfluoroheptanoic acid	ng/L	N/A	ND		ND	ND	
PFHxA Perfluorohexanoic acid	ng/L	N/A	ND		ND	ND	
PFDA Perfluorodecanoic acid	ng/L	N/A	ND		ND	ND	
PFUnA Perfluorodecanoic acid	ng/L	N/A	ND		ND	ND	
PFDoA Perfluorododecanoic acid	ng/L	N/A	ND		ND	ND	
ADONA 4,8-Dioxa-3H-perfluorononon	ng/L	N/A	ND		ND	ND	
9CI-PF3ONS	ng/L	N/A	ND		ND	ND	
HFPO-DA Hexafluoropropylene oxide dimer acid	ng/L	N/A	ND		ND	ND	
11CI-PF3OUds	ng/L	N/A	ND		ND	ND	

4:2FTS 1H,1H,2H,2H-Perfluorohexane sulfonic acid	ng/L	N/A	ND		ND	ND
6:2FTS 1H,1H,2H,2H Perfluorooctane sulfonic acid	ng/L	N/A	ND		ND	ND
8:2FTS 1H,1H,2H,2H-perfluorodecane sulfonic acid	ng/L	N/A	ND		ND	ND
NFDHA Nonafluoro-3,6-dioxaheptanoic acid	ng/L	N/A	ND		ND	ND
PFBA Perfluorobutanoic acid	ng/L	N/A	ND		ND	ND
PFHpS Perfluoroheptanesulfonic acid	ng/L	N/A	ND		ND	ND
PFMBA Perfluoro-4-methoxybutanoic acid	ng/L	N/A	ND		ND	ND
PFMPA Perfluoro-3-methoxybutanoic acid	ng/L	N/A	ND		ND	ND
PFPeA Perfluoropentanoic acid	ng/L	N/A	ND		ND	ND
PFPeS Perfluoropentanesulfonic acid	ng/L	N/A	ND		ND	ND
PFEESA Perfluoro(2-ethoxyethane)sulfonic acid	ng/L	N/A	ND		ND	ND

Abbreviations: Sampled ND=Not Detected

MCL=Maximum Contaminant Level-The highest level of a contaminate allowed in drinking water